



SINTEF

New environmental constraints – Impacts on the power system

Anders Arvesen, Ingeborg Graabak, Mari Haugen, Lennart Schönfelder,
Atle Harby, Birger Mo

User Meeting Hydro Scheduling, 28 November 2023

Image: Frankemann / CC BY-SA 4.0,
Storglomvatnet og Svartisen
<https://commons.wikimedia.org/w/index.php?curid=108875840>

Technology for a better society


Introduction

- Many concessions for hydropower are undergoing revision, introducing more environmental restrictions
- There are concerns this will result in power loss and reduced flexibility
- Project "Nye miljørestriksjoner – samlet innvirkning på kraftsystem" ("SumEffekt")
- SumEffekt's main aim is to provide new understanding of the effects of new environmental restrictions on the power system



Vannkraftkonsesjoner
som kan revideres innen 2022
Nasjonal gjennomgang og forslag til prioritering

49
2013




R
A
P
P
O
R
T

The project

- IPN Innovation Project (2020-2023)
- Project lead: Fornybar Norge (Solgun Furnes)
- User partners: Fornybar Norge, Statkraft, Å Energi, Hydro Energi, Hafslund-Eco, Eviny, Energiforsk, Energiforetagen, SFE Produksjon, Sira-Kvina Kraftselskap, Trønderenergi, Skagerak Kraft, NTE Energi, Statnett, NVE
- SINTEF Energy Research: Ingeborg Graabak (lead), Mari Haugen, Lennart Schönfelder, Atle Harby, Birger Mo, Anders Arvesen




Overall project method






FanSi model

- Fundamental long-term market model
- Detailed treatment of hydropower
- Simulates each week for historical weather years
- Solves sequences of stochastic optimization problems
- Formal optimization, individual water values per reservoir



Credit bottom figure: Arild Helseth, SINTEF Energi





SINTEF

Environmental restrictions analyzed

- **Reservoir restriction (108)**

Inflow must be used for filling up reservoir in summer period. Two approaches:


- Restricted use of local inflow only (our default)
- Restricted use of all inflow including discharges

- **Minimum bypass flow (148)**

Two methods:

- Q95
- Q95 with site-specific adjustments (our default)


- **Minimum discharge flow (29)**



Scenarios analyzed


Scenario name	Environmental constraints	Scenario characteristics
Base		
Base_R-Q	Reservoir, flow	
Base_EMPS		EMPS model (replacing FanSi)
Base_EMPS_R-Q	Reservoir, flow	EMPS model (replacing FanSi)
Base_R	Reservoir	
Base_Q	Flow	
Base_R*-Q	Reservoir (strong), flow	
Base_R-Q*	Reservoir, flow (strong, Q95)	
LowDem		Low demand
LowDem_R-Q	Reservoir, flow	Low demand
HighDem		High demand
HighDem_R-Q	Reservoir, flow	High demand
HighDem_HighSolar		High demand, high solar production
HighDem_HighSolar_R-Q		High demand, high solar production
HighPrice		High fuel and CO ₂ prices
HighPrice_R-Q	Reservoir, flow	High fuel and CO ₂ prices
LowTransm		Low transmission
LowTransm_R-Q	Reservoir, flow	Low transmission

National power balance in three scenarios



Reduction in average annual hydropower


Average annual reduction in hydropower (%) :



- We estimate average annual reduction 3 TWh (2%)
- Primarily because of minimum bypass flow requirements
- Estimate is consistent across scenarios for the power system

Increase in average annual power price

Change in average annual power price (%)




- We estimate average increase in power price of 1-2% (1-2 EUR MWh⁻¹)
- Primarily because of minimum bypass flow requirements
- This estimate is consistent across scenarios for the power system


Some individual periods show marked price increases (example shown for 1996)

- Simulations show incidents of price increases in weeks 18-22
- Effect is mainly attributable to reservoir restrictions
- Such events are relatively few in the results, but at the same time probably underestimated by FanSi


a) Total inflow, Norway, weeks 12-22, Base




b) Temperature-dependent demand, Norway, weeks 12-22, Base



c) Total reservoir fillings, Norway, weeks 12-22, Base




d) Hydropower production, power price, 1996, Norway, Base_R-Q




Some periods show increase in flooding (example for 2015, Gråsjøen)

- Reservoir restrictions lead to accelerated increases in simulated reservoir fillings from week 18
- This can result in flooding during summer and fall
- Example shown for Gråsjøen, which is assigned a new reservoir restriction in our analysis


Reservoir filling, module "Graasjoe", weeks 12-22, Base




c) Reservoir fillings, "Graasjoe", weeks 12-22, 2015



e) Hydropower production, "Graasjoe", at three-hourly time resolution, week 25-28, Base and Base_R-Q



f) Flooding for "Graasjoe" and power price for "Norgemidt", 2015, week 25-28, Base and Base_R-Q






SINTEF

Conclusions and additional remarks

- We estimate average **hydropower reduction 3 TWh** and average **power price increase 1-2%**
- **Two types of effects in single periods:**
 - 1) Marked price increases in weeks 18-22
 - 2) Flooding increases in summer-fall
- Loss of flexibility due to restrictions result in **greater need to utilize other sources of flexibility**
- Additional simulation results from Primod show **lower availability of spinning reserve capacity in weeks 18-24**
- **There is uncertainty**
 - From assumptions and estimates about environmental constraints
 - From aggressive reservoir scheduling in FanSi simulations

Annual average, FanSi, scenario Base:






SINTEF

Technology for a better society

Reservoir fillings with FanSi and EMPS





SINTEF

Reservoir fillings with and without restrictions (FanSi)

