

Benchmarking of power cycles with CO₂ capture


The impact of the chosen framework

4th Trondheim Conference on CO₂ Capture, Transport
and Storage


Kristin Jordal, SINTEF Energy Research

The benchmarking activity at SINTEF/NTNU within BIG CO2


- Nine different power cycles with CO₂ capture evaluated
- Fuel is natural gas
- Reference case is a gas turbine combined cycle of 386 MW and a thermal efficiency of **56.7%**
- The work has been presented at GHGT-7 and in *Energy*




Amine absorption (post combustion)



Oxyfuel CC



Pre-combustion capture with ATR




About quantitative benchmarking

- The methodology for general thermodynamic studies of different power cycles is well established - it is known what process conditions give a high thermal efficiency
- CO₂ capture and compression is a new element to be included in power cycles
- Benchmarking of different power cycles with CO₂ capture against a reference case without capture has become an acknowledged method to evaluate the impact of CO₂ capture on power cycle efficiency (and cost)
- The boundary for a power plant with CO₂ capture is more complex than that of a standard power plant

"My" power plant boundary 10 years ago...

Ambient boundary




$$\eta_{th} = \frac{\text{Power output}}{\text{Fuel input}}$$

Power plant boundary - - - -

Picture of Västhamnsverket in Helsingborg, Sweden

The power plant boundary with CO₂ capture

Ambient boundary





$$\eta_{th} = \frac{\text{Power output}}{\text{Fuel input}}$$

Framework selection



- Standard boundary conditions or site specific?
 - "Standard" boundary conditions, as far as possible, make the results more of general interest
 - Site-specific boundary conditions give a more true picture for a selected site or geographic area
 - Ambient temperature
 - Cooling water temperature
 - Natural gas delivery conditions (LNG or gas?)
 - CO₂ final pressure
 - Oxygen production on site?
- What technology level do we want to reflect?
 - Current (known) technology status – previous SINTEF benchmarking
 - Estimated future technology, when CO₂ capture is likely to be generally adopted for new power plants – topic in this presentation
 - Purpose is to present an idea of what could be the development potential of some different capture technologies

Site-specific conditions: impact of cooling water temperature (=condenser pressure)



- Relative gain from reduced cooling water temperature (right picture) based on LP turbine in combined cycle only.
- Value reduced when considering the entire turbine train with multiple steam extractions.


Example of framework selection: Future technology levels

Parameter	Previous benchmarking	~5-10 years (?)	~15-20 years(?)
GT combustor outlet temperature [°C]	1328	1428	1528
GT max blade temperature (rough estimate)	900	940	980
Max steam temperature [°C]	560	600 (done today already)	700 (goal of R&D programs), 656 max in this work
HP/IP steam turbine inlet pressure [bar]	111/27	Result of optimisation	Result of optimisation (HP supercritical?)
Amine re-boiler steam requirement [kJ/kg CO ₂]	3.4 (low figure!)	2.8	1.5 (unrealistic for temp-swing only)

Each new technology level requires a new reference case without CO₂ capture!


Establishing new reference cases (1): Gas turbine modelling, "future technology"

- A realistic generic gas turbine required when increasing the combustion temperature
- Temperature increase possible due to increased materials temperature and better blade cooling
- Pressure ratio adapted for anticipated exhaust temperature




Establishing new reference cases (2): Combined cycle modelling

- For each new gas turbine, a new reference combined cycle must be established
- We cannot compare a CO₂ capture cycle based on advanced power plant data against a reference cycle reflecting older technology
- Efficiency optimisation in this case was done in GTPRO



T_g [°C]	P_{el} [MW]	Efficiency [%]	Steam data [bar/°C/°C]
1328	386	56.7	111/560/560
1428	411	57.9	111/560/560
1428	414	58.2	140/580/580
1528	436	58.8	111/560/560
1528	440	59.4	180/600/600


Post combustion capture – development possibilities



N.B.! Upper limit values are extremely optimistic!


Should be regarded as an extreme limit for the potential for this technology

Oxyfuel CC development possibilities




- Capture is more integrated in the oxyfuel CC than in the post combustion cycle.
- More difficult to push performance parameters towards the "extreme" in a computational exercise
- Oxyfuel CC penalised by consistent framework for steam bottoming cycle???

Pre-combustion with ATR




- CO₂ capture in pre-combustion with ATR even further integrated than in oxyfuel CC
- No benefit (in current process layout) from increasing GT pressure ratio
- Not possible (in current process layout) to use improved steam data from reference CC
- Only technology improvement with positive impact on performance is increased combustor outlet temperature

Chemical Looping potential



Source: Naqvi R., 2006, "Analysis of Natural Gas-Fired Power Cycles with Chemical Looping Combustion for CO₂ capture", Doctoral Theses at NTNU, 2006:138.

Summary, future development potential



Concluding remarks, future development potential

- When considering future development potential, the same boundary conditions were applied as in previous benchmarking
- New reference combined cycles were established to reflect the anticipated technology development
- Post combustion capture has a low degree of integration with the power plant, and it is easy to produce theoretical results with increased cycle efficiency, beyond a realistic limit
- It appears from this work that the more integrated the CO₂ capture into the cycle, the more difficult it could actually be to improve cycle efficiency beyond combustor outlet temperature improvements
 - The development potential with evolving technology should be useful to consider for a manufacturer before deciding to pursue the development of a certain technology

Concluding remark: impact of chosen framework for CO₂ capture studies

- Main issue: be careful when presenting results and/or when interpreting results that are presented to you!
 - Is the framework for the study consistent?
 - What is included in the efficiency calculation?
 - What are the boundary conditions? (site specific? ISO standard?)
 - What is the technology level? Is it realistic? Outdated?
 - What is the reference case without CO₂ capture? Does it have the same framework as the case(s) with CO₂ capture?

Thank you for your attention!



BIG CO2 benchmarking: Stream input data (boundary conditions)


Fuel feed stream		
<i>Composition</i>		
N2	[mole%]	0,9
CO2	[mole%]	0,7
C1	[mole%]	82
C2	[mole%]	9,4
C3	[mole%]	4,7
C4	[mole%]	1,6
C5+	[mole%]	0,7
<i>Properties</i>		
Pressure	[bar a]	50
Temperature	[°C]	15
Molecular weight	[g/mol]	20,05
Density	[kg/Sm3]	0,851
<i>Conditions</i>		
lower heating value	[kJ/Sm3]	40448
lower heating value	[kJ/kg]	47594
Air feed stream		
<i>Composition</i>		
N2	[mole%]	77,3
CO2	[mole%]	0,03
H2O	[mole%]	1,01
Ar	[mole%]	0,92
O2	[mole%]	20,74
<i>Properties</i>		
Pressure	[bar a]	1,013
Temperature	[°C]	15

Oxygen feed stream		
<i>Composition</i>		
O2	[mole%]	95
N2	[mole%]	2
Ar	[mole%]	3
<i>Properties</i>		
Pressure	[bar a]	2,38
Temperature	[°C]	15
<i>Conditions</i>		
Energy production requirement	kJ/kg O2	812
CO2 outlet		
<i>Composition</i>		
CO2 concentration	[mole%]	88,6-99,8
<i>Properties</i>		
Pressure	[bar a]	200
Temperature	[°C]	30


BIG CO2 benchmarking: Computational assumptions (inside the power plant)

Heat exchangers			Steam power cycle		
Pressure drop	[%]	3	Max steam temperature, pure steam cycle	[°C]	560
ΔT_{\min} gas/gas	[°C]	30	HP steam turbine inlet pressure	[bar a]	111
ΔT_{\min} gas/liquid	[°C]	20	IP steam turbine inlet pressure	[bar a]	27
HRSG ΔT steam out/exhaust in	[°C]	20	LP steam turbine inlet pressure	[bar a]	4
HRSG pinch point	[°C]	10	Max temperature WC HP turbine	[°C]	900
CO2 compression intercooler temperature	[°C]	30	Deaerator pressure	[bar a]	1,2
Gas side pressure drop through HRSG	[mbar]	40	Condenser pressure, pure steam cycle	[bar a]	0,04
Reactors			Condenser pressure, Water Cycle	[bar a]	0,045
GT Combustor and reactor pressure drop	[%]	5	Condenser pressure, Graz cycle	[bar a]	0,046
Duct burner pressure drop	[%]	1	Condenser pressure, Oxyfuel CC	[bar a]	1,01
Combustor outlet temperature (max)	[°C]	1328	Cooling water inlet temperature	[°C]	8
Reactor outlet temperature, CLC and AZEP	[°C]	1200	Cooling water outlet temperature	[°C]	18
Turbomachinery efficiencies			CO2-capture-specific cycle units		
Main GT Compressor polytropic efficiency	[%]	91	CO2 absorption recovery rate, ATR and post combustion	[%]	90
Main GT Uncooled turbine polytropic efficiency	[%]	91	CO2 stripper outlet pressure, ATR and post combustion	[bar a]	1,01
Small compressor polytropic efficiency	[%]	87	Amine re-boiler steam requirement	[MJ/kg CO2]	3,4
Small turbine polytropic efficiency	[%]	87	Pressure drop in absorption column	[mbar]	150
CO2 compression isentropic efficiency stage 1	[%]	85	Methane conversion MSR-H2	[%]	99,8
CO2 compression isentropic efficiency stage 2	[%]	80	Shift reaction conversion MSR-H2	[%]	99
CO2 compression isentropic efficiency stage 3	[%]	75	H2 separation MSR-H2	[%]	99,6
CO2 compression isentropic efficiency stage 4	[%]	75	CLC degree of carrier oxidation	[%]	100
SOFC/GT cycle compressor polytropic efficiency	[%]	87,5	CLC degree of carrier reduction	[%]	70
SOFC/GT cycle turbine polytropic efficiency	[%]	87,5	CLC degree of fuel utilisation	[%]	100
AZEP and SOFC/GT recirc compressor polytropic efficiency	[%]	50	Auxiliaries		
HP steam turbine isentropic efficiency	[%]	92	Generator mechanical efficiency	[%]	98
IP steam turbine isentropic efficiency	[%]	92	O2 and CO2 compression mechanical drive efficiency	[%]	95
LP steam turbine isentropic efficiency	[%]	89	Auxiliary power requirements (of net plant output)	[%]	1
Pump efficiency (incl. motor drive)	[%]	75			
Note: Small compressor/turbine refers to H2O/CO2 recirculation compressor, ATR and MSR-H2 fuel compressors, MSR-H2, CLC and AZEP CO2/steam turbines					


Konsept 1a: Eksosgassrensing med amin



Oxy-fuel CC



Konsept 2a: Reformering av hydrokarboner vha autotermisk reaktor (ATR)



Model assumptions:

- 15 bar in ATR
- steam-carbon ratio = 2
- $T_{out\ ATR} = 900\ ^\circ\text{C}$
- H1 and H2 are boilers
- Steam cycle: 3 pressure levels (4, 27 og 111 bar) and reheat
- Condenser heat used in the absorption stripper
- 90 % CO₂ is removed by absorption