



# Design and Optimisation of Offshore Grids in Baltic Sea for Scenario Year 2030

Vin Cent Tai & Kjetil Uhlen

Norwegian University of Science and Technology

**EERA Deepwind'2014**  
Trondheim, Norway  
22 – 24 / Jan / 2013

# Outline

---

- Offshore Grid Design
  - Objective
  - Design flow chart
- Case Study : Baltic Sea 2030
- Design inputs
  - *Objective function*
  - *Wind power model*
  - *Load model*
  - *Generator model*
- Preliminary Results
  - *Case I*
  - *Case II*
- *Future Work*

# Offshore Grid Design

## Objective

*OffshoreDC* project [1] WP-5:


- Find an optimal grid structure taking into account:
  - Wind power variations
  - Stochastic power prices
  - On- and offshore load and generation scenarios
- Use formal optimization for a structured approach to finding good grid layouts
  - Huge number of possible grid structures
  - Combinatorial problem solved efficiently by optimization tools
- Results:
  - Which cables to build & capacity on the cables
  - Gives valuable decision support, but:
  - Must be combined with market/network model in an iterative procedure

---


[1] [www.offshoredc.dk](http://www.offshoredc.dk)

# Offshore Grid Design

## Design Flow Chart



# Case Study : Baltic Sea 2030



- **Problem :** How to connect the wind farms to the onshore grids?
  - # of offshore windfarms : 97
  - # of onshore substations : 18
  - # of market areas : 12
  - # of combinations =  $2^{N(N-1)/2}$
- To reduce the # of combinations:
  - Windfarms owned by the same country
  - Geographical size  $\pm 100\text{km}$
  - Cluster size  $\pm 2000\text{MW}$
- Results : Total windfarm clusters = 32

## Network Optimisation Tool : NetOp [1]

- Mixed Integer Linear Programming (MILP Problem)
- Objective function:

$$\min(C_{Tot}^{branch} + C_{Tot}^{node} + C_{Tot}^{geno})$$

---

[1] H.G.Svendsen (2013). Planning tool for clustering and optimised grid connection of offshore wind farms. Energy Procedia 35, pp. 297 – 306.

# Design Inputs

## Wind Power Model

Table 1: Total installed wind power capacity for each country by 2030 [1].

#	Country	Installed Capacity [MW]
1	Germany	4737
2	Denmark	3334
3	Sweden	8413
4	Finland	5433
5	Poland	500
6	Estonia	2602
7	Lithuania	1000
8	Latvia	1100

**Assumption:** The wind power generation profile is the same across the Baltic sea. (**Not realistic!!**)

### Current Model:

- Wind power time series data for wind farms in the Kringersflak area [2].
- Aggregate wind power output of the wind farms and normalise it against the total capacity of the wind farms:

$$W_{profile}(t) = \frac{\sum_{n=i} P_{wf,i}(t)}{\sum_{n=i} P_{wf,i}^{max}}$$

**Next step:** Use CorWind [3] model.

[1] N. Cutululis (N.A). TWENTIES Deliverable 16.1: Offshore wind power data, unpublished.

[2] H.G.Svendsen (2013). Planning tool for clustering and optimised grid connection of offshore wind farms. Energy Procedia 35, pp. 297 – 306.

[3] P. Sorensen et al., (2009). Power fluctuation from large wind farms – Final report.

Table 2 : Wind clusters and their corresponding onshore connection points. The wind clusters are connected radially to the connection points closest to them as initial *NetOp* input.

#	Country	Cluster Name	Capacity [MW]	Latitude	Longitude	Connection Point	Case
1	DE	DE-1	1780	54.8115	14.1094	Lubmin	2
2	DE	DE-2	1800	54.8135	13.7852	Lubmin	2
3	DE	DE-3	1090	54.4579	12.2551	Bentwisch	2
4	DK	DK-1	890	54.5510	11.6587	Bjaerverskov	2
5	DK	DK-2	180	55.6520	12.5810	Bjaerveskov	2
6	DK	DK-3	1980	55.0298	12.9970	Bjaerveskov	2
7	DK	DK-4	160	54.9080	14.7035	Bjaerveskov	2
8	DK	DK-5	150	56.5000	12.0950	Trige	2
9	FI	FI-1	2440	65.6558	24.4852	Isohara	1
10	FI	FI-2	1220	65.2093	24.7811	Isohara	1
11	FI	FI-3	490	64.7023	24.2873	Pyhajoki	1
12	FI	FI-4	620	61.9607	21.2616	Rauma	1
13	FI	FI-5	10	60.1340	20.8890	Rauma	1
14	FI	FI-6	160	59.8590	23.8880	Espoo	1
15	FI	FI-7	500	60.1170	19.9000	Rauma	1



Table 2 : (continued..)

#	Country	Cluster Name	Capacity [MW]	Latitude	Longitude	Connection Point	Case
16	SE	SE-1	1420	56.6831	12.1947	Breared	2
17	SE	SE-2	600	55.8781	14.6704	Hemsjo	2
18	SE	SE-3	920	55.0700	13.1030	Hurva	2
19	SE	SE-4	1300	55.5110	12.7790	Hurva	2
20	SE	SE-5	1600	56.1899	16.1460	Hemsjo	2
21	SE	SE-6	550	57.0576	18.0397	Hemsjo	2
22	SE	SE-7	1010	61.1328	17.5281	Stockholm	1
23	SE	SE-8	920	63.5470	20.3350	Sundsvall	1
24	SE	SE-9	60	65.0700	22.0300	Svartbyn	1
25	PO	PO-1	180	54.9914	18.4973	Slupsk	2
26	PO	PO-2	230	55.0601	17.3409	Slupsk	2
27	PO	PO-3	90	54.5461	15.8235	Slupsk	2
28	EE	EE-1	1580	59.2572	23.2171	Lihula	1
29	EE	EE-2	520	58.0541	23.7503	Lihula	1
30	EE	EE-3	500	58.8670	22.5830	Lihula	1
31	LV	LV-1	1000	55.8687	20.6711	Grobina	2
32	LT	LT-1	1100	56.7656	20.8797	Klaipeda	2



# Design Inputs

## Load Model

Table 3 : Annual demand of each price area in 2030.

#	Price Area	Load Demand [GWh]	Case study
1	DK1	23347	1
2	DK2	15735	1
3	DE	581128	1
4	PO	165344	1
5	FI	90922	2
6	LI	10922	1
7	LT	8699	1
8	EE	10921	1
9	SE1	12461	2
10	SE2	14631	2
11	SE3	90392	2
12	SE4	25693	1

$$L_{p.area}^{2030} = L_{p.area}^{2012} \times \frac{L_{country}^{2030}}{L_{country}^{2012}}$$

### Note:

$L_{p.area}^{2012}$  Extracted from time series data from [ENTSO-E](#)  
 $L_{country}^{2012}$

$L_{country}^{2030}$  Forecast data from [1]

**Assumption:** The load consumption pattern of each price area does not vary too much from 2012's pattern.

[1] S.Uski-Joutsenvuo and N. Helisto. Initializing network simulations for case studies of offshore wind power and offshore DC grid integration in the power system of Northern Europe. 12Th Wind Integration Workshop<sup>10</sup>, 22-24 Oct 2013, London, UK.



# Design Inputs

## Generator Model

- Generators other than wind power generators are modelled as power prices in the relevant price areas.

### Assumptions:


- Transmission capacity within each country is unlimited.
- Cost of generation is not affected by wind power.
- Maximum power generation (exclude wind) is as high as the total demand of the respective price area.

### Power prices :

- 2012 time series data is used.
- Sweden, Finland, & Estonia ([www.nordpoolspot.com](http://www.nordpoolspot.com))
- Germany ([www.eex.com](http://www.eex.com))
- Poland ([www.pse-operator.pl](http://www.pse-operator.pl))
- Latvia & Lithuania (assume the same as Estonia's)

# Preliminary Results


## Case Studies



# Preliminary Results

## Case I

- SE1 – SE3 :
  - WFs – substations:
    - Radial Connections
    - Direct DC > 70 km
- Northern FI:
  - WFs – substations:
    - AC lines  $\leq$  70 km
- Southern FI & EE:
  - Offshore connection point 307 collects power from WFs 208 (1580 MW capacity) & 211 (10 MW capacity).
  - Most power flows to FI. Mean flows:
    - 211  $\rightarrow$  307 : 540 MW
    - 208  $\rightarrow$  307 : 4 MW
    - 307  $\rightarrow$  104 : 520 MW
- Wind power in EE ( $103 \rightarrow 305$ ):
  - Total 660 MW from WFs 211, 212 and 213.



# Preliminary Results

## Case I

Table 4 : Key results for case I.

from node 3	to node	Branch type	Distance (km)	# of cables	Capacity (MW)	mean flow (MW) 1 → 2	mean flow (MW) 1 ← 2
201	102	3	236	2	1010	460	0
202	107	3	202	1	920	420	0
203	101	3	78	1	60	30	0
204	106	1	15	4	2440	1100	0
205	106	1	66	2	1220	560	0
206	105	1	46	1	480	220	0
207	104	3	92	1	620	280	0
209	108	1	53	1	160	70	0
210	104	3	149	1	500	230	0
211	103	1	69	1	390	240	40
212	103	3	78	1	520	240	0
213	103	3	78	1	500	230	0
102	303	1	43	0	10000	440	0



# Preliminary Results

## Case I


Table 4 : (continued.)

from node	to node	Branch type	Distance (km)	# of cables	Capacity (MW)	mean flow (MW) 1 → 2	mean flow (MW) 1 ← 2
107	302	1	4	0	10000	400	0
101	301	1	23	0	10000	20	0
106	304	1	627	0	10000	1650	0
105	304	1	461	0	10000	220	0
104	304	1	212	0	10000	990	20
108	304	1	22	0	10000	70	0
103	305	1	90	0	10000	660	10
208	307	1	42	1	10	4	0
211	307	3	123	2	1900	540	30
307	104	3	130	2	1840	520	30

Note: Node 307 is the offshore node suggested by NetOp.

# Preliminary Results


## Case II



# Preliminary Results


## Case I

- SE4, DK1 and DE are connected at point 309.
- $103 \rightarrow 309$  (AC cable): 540 MW mean flow
- Wind power from WFs 203, 204, 208, 209 and 210 are collected at offshore node 309.
- $309 \rightarrow 107$  (4 DC cables): 2680 MW
- 3-terminal HVDC connects 103, 309, 107. Power transfer 900 MW from 103 to 107.



# Preliminary Results

## Case II





# Preliminary Results

## Case II

Table 5 : Key results for case II.

from node	to node	Branch type	Distance (km)	# of cables	Capacity (MW)	mean flow (MW) 1 → 2	mean flow (MW) 1 ← 2
201	101	1	57	3	1422	640	0
202	102	1	50	1	604	270	0
204	103	1	51	1	593	210	220
205	102	3	91	1	895	450	100
206	102	3	220	1	810	310	30
207	104	3	97	1	884	400	0
208	104	1	48	1	689	220	310
211	105	3	115	1	147	70	0
212	107	3	93	2	1778	800	0
213	107	3	86	2	1793	810	0
214	108	1	39	2	1084	490	0
215	109	3	112	1	183	80	0
216	109	1	61	1	231	100	0



# Preliminary Results

## Case I

Table 5 : (continued.)

from node	to node	Branch type	Distance (km)	# of cables	Capacity (MW)	mean flow (MW) 1 → 2	mean flow (MW) 1 ← 2
217	109	3	72	1	90	40	0
218	110	1	32	2	830	470	12
219	111	1	28	2	1000	450	0
101	301	1	128	0	10000	940	300
102	301	1	133	0	10000	960	100
103	301	1	34	0	10000	150	1490
104	302	1	49	0	10000	510	220
105	303	1	13	0	10000	60	0
107	304	1	153	0	10000	5270	390
108	304	1	125	0	10000	820	330
109	305	1	377	0	10000	670	100
110	306	1	185	0	10000	470	12
111	307	1	293	0	10000	450	0



# Preliminary Results

## Case II

Table 5 : (continued.)

from node	to node	Branch type	Distance (km)	# of cables	Capacity (MW)	mean flow (MW) 1 → 2	mean flow (MW) 1 ← 2
203	309	1	12	2	920	420	0
204	309	1	47	1	700	620	20
205	310	1	56	1	700	470	110
206	308	3	131	1	270	70	100
208	309	1	67	1	700	350	180
209	309	1	20	3	1970	890	0
210	309	3	101	1	160	70	0
218	308	1	56	1	270	100	70
309	103	1	62	1	700	60	540
309	107	3	124	4	3650	2680	70
310	109	3	133	1	700	480	110

Note : 308 – 310 are offshore nodes resulted from the optimisation.

# Preliminary Results

## Case II

Table 5 : (continued.)

from node	to node	Branch type	Distance (km)	# of cables	Capacity (MW)	mean flow (MW) 1 → 2	mean flow (MW) 1 ← 2
1309	1103	2	62	1	1000	70	900
1309	1107	2	124	1	1000	900	70
1103	103	4	0.0	2	1020	60	910
1107	107	4	0.0	1	1000	900	70



# Future Work

- Re-run the cases I & II with *CorWind* models.
- “Close the loop”:
  - Evaluate the technical feasibility of the grids
  - Investigate the how the grids will impact on the power market

# Thanks!!