





European Best Practice Guidelines for the Evaluation of CO₂ Capture Technologies

Trondheim – 16/06/2011

Authors: <u>Rahul Anantharaman</u>, Olav Bolland, Nick Booth, Eva van Dorst, Clas Ekstrom, Eva Sanchez Fernandez, Ennio Macchi, Giampaolo Manzolini, Djordje Nikolic, Mark Prins, Sina Rezvani, Laurence Robinson



Outline

- The European Benchmarking Task Force
- Results achieved
 - The Common Framework Definition Document (CFDD)
 - Test Cases for reference
 - Economic assessment
- Summary





2





The European Benchmarking Task Force

- Consistent and transparent comparison of CO₂ capture technologies is important and difficult
- A team was created with representatives from three FP7 projects – CAESAR, CESAR and DECARBit to
 - Elaborate a Common Framework Definition Document (CFDD)
 - Define and analyse set of test cases
- The results of the work were to be made public and easily accessible to the CCS community









1. The Common Framework Definition Document

- The purpose is NOT to recommend any values as the best or the right ones for future power plants
- The purpose IS to define a set of parameters to ensure that technical and economic comparison of novel cycles involving novel technologies is done in a consistent and fair way
- The choice of parameters is justified and the source acknowledged, for example IEA, DOE, EU, specialized publications, other projects, expert opinion and others are identified










1. The Common Framework DD

Operating & cost parameters of components based on novel technologies











Three cases without and with CO₂ capture

- Integrated Gasification Combined Cycle
- Natural Gas Combined Cycle
- Ultra Super Critical Pulverized Coal
- The purpose is NOT to compare power generation technologies
- The purpose IS to propose references for comparisons of novel cycles within the same power generation technology PF, IGCC, NGCC
- Contents of the report, for each case
 - Cycle description in detail
 - Heat and mass balance analysis
 - Operational characteristics
 - Operational performance
 - Comparison of results independently produced by two of the three projects









General assumptions

- Plants operating at nominal base load
- 'New and clean' conditions
- Assessment of the Specific Primary Energy Consumption for CO₂ Avoided – SPECCA:

$$SPECCA = \frac{HR - HR_{REF}}{E_{REF} - E} = \frac{3600 \cdot \left(\frac{1}{\eta} - \frac{1}{\eta_{REF}}\right)}{E_{REF} - E}$$

- HR = heat rate of the plants
- $E = CO_2$ emission rate of the plants
- REF = reference plant without CO₂ capture










Integrated Gasification Combined Cycle with capture



Integrated Gasification Combined Cycle with capture

	Comparison of some characteristics and performance				
DECARBit	[DECARBit MWe	CAESAR MWe		
and	GT output	282.87	304.97		
CAESAR	ST output	168.46	175.95		
	Gross elec. power output	457.17	491.09		
	Total aux. power consumption	104.43	107.61		
	Net electric power out.	352.74	383.48		
	Efficiency	36.66	36.40		
	Specific emissions kg/MWh	85.28	97.54		
	SPECCA	3.30	3.67		










Natural Gas Combined Cycle with capture











Natural Gas Combined Cycle with capture

	Comparison of some characteristics and performance				
	Number of Gas Turbines	CAESAR 2	CESAR 1		
CAESAR and CESAR	GT power output MWe ST power output MWe Gross elec. power output MWe Total aux. power cons. MWe Net electric power out. MWe Efficiency Specific emissions kg/MWh SPECCA MJ/kgCO ₂	$\begin{array}{c} 272.10\\ 215.70\\ 754.90\\ 45.20\\ 709.70\\ 49.90\\ 36.20\\ 3.30\end{array}$	289.20 99.10 388.30 31.50 356.80 49.30 41.90 3.61		










Ultra Supercritical Pulverized Coal with capture



12

SEVENTH FRAMEWORK

Ultra Supercritical Pulverized Coal with capture

	Comparison of some characteristics and performance calculated by two projects			
CESAR and CAESAR	ST gross power output Total aux. power consumption Net electric power output Efficiency with capture CO2 emitted kg/MWh SPECCA MJ/kgCO ₂	CESAR MWe 684.20 135.00 549.20 33.40 104.70 4.35	CAESAR MWe 686.90 124.50 562.40 33.50 104.00 4.16	









3. Economic assessment *Parameters and assumptions* -

- Long term future economic developments are hard to predict, so 2008 was chosen as the reference year (start of the three projects)
- Average Chemical Engineering Plant Cost Index (CEPCI) of 576% is assumed for 2008 (100% for 1958)
- Power plant economic lifetime = 25 years
 - 40 years also considered for coal power plants, as in ENCAP, CASTOR and CESAR
 - 15 years also considered for natural gas power plants
- Construction time
 - 4 years for coal and lignite
 - 3 years for natural gas





3. Economic assessment - Method -

- Estimations are made of
 - Capital costs
 - Fixed and variable operation and maintenance costs
 - Fuel costs
- Capital investment cost is calculated with
 - Bottom-up approach using parameters derived from the heat and mass balance calculations
 - Top-down approach based on equipment supplier estimates of entire Engineering, Procurement and Construction Costs





3. Economic assessment

- Evaluation criteria -

Economic viability measured through

- CO₂ avoidance cost
- Breakeven Electricity Selling Price (BESP)
 - capital investment costs
 - fixed O&M costs (e.g. Labour)
 - variable O&M costs (consumables)
 - fuel costs
- A sensitivity analysis is made with respect to main assumptions (e.g. specific investment costs, fuels, etc.)





3. Economic assessment - Test cases -


Advanced super-critical pulverized coal

- Top down approach
 - Engineering, Procurement and Construction costs quote requested to power plant and turbine suppliers for the entire power plant in 2008, with uncertainty of + - 30%
 - Suppliers also requested to estimate fixed and variable operating costs
 - For the CO₂ capture plant, quotes for the main equipment were requested from several vendors, for calculated equipment sizes
 - Installation costs estimated as percentages of the equipment costs





3. Economic assessment - Advanced super-critical pulverized coal -







3. Economic assessment - Test cases -

Integrated gasification combined cycle

Bottom up approach - equipment and installation costs estimated for:


Coal handling Gasifier Gas turbine Steam turbine Heat recovery steam generator Low temperature heat recovery Cooling Air separation unit

Ash handling Acid gas removal Gas cleaning Water treatment Water gas shift reactor Claus burner Selexol plant CO₂ compression unit





3. Economic assessment - Integrated gasification combined cycle -







3. Economic assessment - Test cases -

Natural gas combined cycle


Bottom up approach - equipment and installation costs estimated for:

Gas turbine GT generator and auxiliaries Steam turbine ST generator and auxiliaries Feedwater and miscellaneous BOP systems MEA CO_2 separation system CO_2 compression unit





3. Economic assessment - Natural gas combined cycle -







Summary

What was achieved

- Common Framework Definition Document
 - Standard parameters and assumptions to be adopted for consistent techno-economic evaluations of Carbon Capture technologies
- Test cases and preliminary benchmarking results from the three projects – technical part
- Test cases and preliminary benchmarking results from the three projects – economic part
- Possible future developments with new EU projects but also with North America and Australia, where a similar interest exists at this moment.











European Benchmarking Task Force







