

# Lessons learnt with hydrogen sampling

Ole S. Kjos  
SINTEF

12/9 - 2019

# Overview

- Fuel quality results
- Sampling methodology
- Sampling experiences
- Shipment
- Analytical comparison
- Filter analysis
- Conclusions



# Introduction

- Sampling  $H_2$  from HRS since 2012
- Experience from 38 gas and 18 particulate samples will be covered here (Hydraite + Hycora)
- 4 European countries
- 4 Sampling campaigns (4 years)



# Fuel quality results

- Results from analysis by SmartChemistry using ASTM methods
- **Main finding is that despite some violations the fuel quality is good**





# Fuel quality results

- Based on analysis from SmartChemistry using ASTM methods
- **Main finding is that despite some violations the fuel quality is good**
- Most common violations are components from air, and hydrocarbons
- No violations for CO, halides or sulphur
- Often an explanation for the violations
- No particulate samples above ISO limits

# Fuel quality violations

| Component                | Limit [ppm] | Average [ppm] | Median [ppm] | Max [ppm] | Violations          |
|--------------------------|-------------|---------------|--------------|-----------|---------------------|
| O <sub>2</sub>           | 5           | 7.3           | 5.7          | 13        | 7 (+1 at the limit) |
| N <sub>2</sub> + Ar      | 100*        | 527           | 398          | 1444      | 6                   |
| CO <sub>2</sub>          | 2           | 5.7           | 5.7          | 5.7       | 1                   |
| Non Methane Hydrocarbons | 2           | 30            | 30           | 30        | 1                   |

# Fuel quality violations

|            | HD-SC1 | HD-SC1 | HY-SC3 | HY-SC2 | HY-SC2 | HY-SC2 | HY-SC2 | HY-SC2 | HY-SC2 | HY-SC1 | HY-SC1 |
|------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Station ID | 1      | 2      | 3      | 4      | 5      | 6      | 7      | 8      | 9      | 3      | 10     |
| THC (C1)   | 0.4346 | 0.1704 | 47     | 0.07   | 0.36   | 0.30   | 0.42   | 5.1    | 0.88   | 0.55   | 0.1    |
| Methane    | 0.41   | 0.14   | 17     | 0.062  | 0.18   | 0.18   | 0.38   | 5.0    | 0.85   | 0.093  | 0.03   |
| Acetone    | 0.009  |        |        | 0.0045 | 0.0069 | 0.0174 | 0.011  | 0.045  | 0.0072 | 0.0078 | 0.0078 |
| O2         | 1.1    | <1     | 1.8    | 11     | 5.7    | 5.2    | 5.4    | 13     | 5.4    | 4.1    | 5.7    |
| He         | <10    | 15     |        |        | 40     |        |        |        |        |        |        |
| N2 & Ar    | 237.48 | 234.47 | 452    | 26     | 18     | 56     | 378    | 419    | 76     | 1444   | 34     |
| N2         | 237    | 234    | 448    | 26     | 18     | 56     | 378    | 416    | 76     | 1443   | 34     |
| Ar         | 0.48   | 0.47   | 4.3    |        |        |        |        | 3.1    |        | 0.67   | 0.46   |
| CO2        | <0.1   | <0.1   | 0.37   |        |        |        |        | 5.7    |        | 0.43   |        |

# Fuel quality violations

|                     | HD-SC1 | HD-SC1 | HY-SC3 | HY-SC2 | HY-SC2 | HY-SC1 | HY-SC1 |
|---------------------|--------|--------|--------|--------|--------|--------|--------|
| Station ID          | 1      | 2      | 3      | 7      | 8      | 3      | 10     |
| THC (C1)            | 0.4346 | 0.1704 | 30     | 0.42   | 5.1    | 0.55   | 0.1    |
| Methane             | 0.41   | 0.14   | 17     | 0.38   | 5.0    | 0.093  | 0.03   |
| O <sub>2</sub>      | 1.1    | <1     | 1.8    | 5.4    | 13     | 4.1    | 5.7    |
| He                  | <10    | 15     |        |        |        |        |        |
| N <sub>2</sub> & Ar | 237.48 | 234.47 | 452    | 378    | 419    | 1444   | 34     |
| N <sub>2</sub>      | 237    | 234    | 448    | 378    | 416    | 1443   | 34     |
| Ar                  | 0.48   | 0.47   | 4.3    |        | 3.1    | 0.67   | 0.46   |
| CO <sub>2</sub>     | <0.1   | <0.1   | 0.37   |        | 5.7    | 0.43   |        |



# Fuel impurities within limits

| Component         | Count | Average excl violations [ppm] |
|-------------------|-------|-------------------------------|
| CH <sub>4</sub>   | 38/38 | 0.77                          |
| Acetone           | 19/38 | 0.012                         |
| Ethane            | 12/38 | 0.59                          |
| EtOH              | 19/38 | 0.040                         |
| Isopropyl Alcohol | 9/38  | 0.015                         |
| Propane           | 25/38 | 0.39                          |
| Toluene           | 8/38  | 0.0061                        |
| Isobutane         | 12/38 | 0.24                          |
| N-butane          | 5/38  | 0.0118                        |

Table shows number of samples where compound is identified, total samples in campaign, average value of detected compounds [ppm]



# Fuel impurities within limits

Table shows number of samples where compound is identified, total samples in campaign, average value of detected compounds [ppm]

| Component                                     | Count | Average [ppm] |
|---|-------|---------------|
| H <sub>2</sub> S                              | 34/38 | 1.49E-5       |
| COS   | 38/38 | 2.99E-5       |
| MTM   | 4/38  | 6.43E-6       |
| CS <sub>2</sub>                               | 12/38 | 3.67E-6       |
| DMS   | 8/38  | 5.19E-5       |
| C <sub>4</sub> Cl <sub>4</sub> F <sub>6</sub> | 38/38 | 0.011         |

# Gas sampling

- Linde H2 Qualitizer
- Parallel sampling
- Sample bottles are evacuated in the lab, equipment can be purged before sampling
- Efficient sampling
- During cascade change station will do a leak-test (pressure monitoring)
  - Sample bottle have to be closed



# Sample containers

Spectraseal treated 10L cylinders used

- Evacuated to 2 mbar and filled to 10 bar with 6.0 H<sub>2</sub> 2x, and then evacuated
- Tracking of cylinders  
→ No carryover

|                    | HY-SC2-10      | HY-SC3-2       |
|--------------------|----------------|----------------|
| THC (C1)           | <b>5.1</b>     | <b>1.7</b>     |
| Methane            | 5.0            | 0.6            |
| Acetone            | 0.045          |                |
| Propane            | 0.066          | 0.018          |
| <b>O2</b>          | <b>13</b>      |                |
| <b>N2 &amp; Ar</b> | <b>419</b>     | <b>8</b>       |
| N2                 | <b>416</b>     | 8.3            |
| Ar                 | 3.1            |                |
| <b>CO2</b>         | <b>5.7</b>     |                |
| <b>CO</b>          | <b>0.015</b>   | <b>0.001</b>   |
| <b>TS</b>          | <b>0.00011</b> | <b>0.00001</b> |
| H2S                | 0.000012       | 0.0000026      |
| COS                | 0.000085       | 0.0000071      |
| CS2                | 0.00001        |                |
| <b>TH</b>          | <b>0.0033</b>  | <b>0.0026</b>  |
| C2Cl2              | 0.0023         |                |
| C4Cl4F6            | 0.0010         | 0.0026         |

# Particulate sampling


- Hydac PSA H70
- Need H<sub>2</sub> amount (HRS)
- Used a 0.2um filter (ASTM) rather than a 5 um filter (iso / Hydac)
- Sensitivity is good with standard deviation 0.1 mg/kg H<sub>2</sub> obtained
- Sufficient to meet the ISO detection limit of 1 mg/kg
- Most samplings have been done in series with Linde qualitizer
- Purging of sampler a possible challenge  
→ Addressed by redesign by HYDAC





# Particulate sampling

- Filter needs to be weighted, handled and changed in clean atmosphere
- Clean room in the lab
- Inflatable glovebox in the field
- Measurements with field blanks proves the concept
- Several discarded samples, no easy way to reset equipment fast (Sampler cold, car full etc.)





# Practical experiences

- No safety incidents, and no events that lead the station to shut down
- Using Linde qualitizer and Hydac PSA H70 does not require station operators to be present (local rules might)
- Sampling will be just a regular filling seen from the station side
  - Refuelling card can be locked after X attempts, can cause challenges due to the need for purging



# Sampling challenges

Need for empty FCEV

- Few FCEV available
- Long time to empty
- Contaminated station = contaminated car (gas)
- Most suited for routine analysis





# Combined sampling

Obtain particulate and gas sample at the same time


- One car for both samples
- Technically not a challenge
- More equipment = Pressure drop and volume
- Which device should be put first
  - Linde first can trap particulates
  - Hydac first can trap sulphur species (more surface)



# Combined sampling

Obtain particulate and gas sample at the same time

- One car for both samples
- Technically not a challenge
- More equipment = Pressure drop and volume
- Which device should be put first
  - Linde first can trap particulates
  - Hydac first can trap sulphur species (more surface)





# Sample shipment

Shipment of pressurized  $H_2$  is challenging

- Different national rules
- Customs
- Transport companies have little experience, handover between local and global carriers a challenge
- HRS is often not a good collection point for carriers
- Using laboratories as collection points for cylinders
- Should be carried out as fast as possible



# Analysis comparison

Until Hydraite project only SC in USA were able to analyse the full standard

- Few options to compare data from independent labs
- Some labs could do part of the analysis
- Hydraite → Europe will shortly have 3 laboratories
- SC samples have to be transferred to smaller bottles → Increases risk for contamination






# Laboratory comparison

|                  | SC       |               | NPL      |               | SC       |               | NPL      |                 | SC |  | NPL |  |
|------------------|----------|---------------|----------|---------------|----------|---------------|----------|-----------------|----|--|-----|--|
|                  | HD-SC1-1 |               | HD-SC1-4 |               | HD-SC1-6 |               | HD-SC1-7 |                 |    |  |     |  |
| N <sub>2</sub>   | 75       | 70 ± 11       | 237      | 231 ± 22      | 8.9      | 7.96 ± 0.42   | 234      | 33.5 ± 1.8      |    |  |     |  |
| Ar               | 0.75     | 0.628 ± 0.016 | 0.48     | 0.336 ± 0.017 | < 0.4    | < 0.30        | 0.47     | < 0.30          |    |  |     |  |
| H <sub>2</sub> O | < 1      | 3.30 ± 0.20   | < 1      | 4.29 ± 0.30   | 1.5      | 6.01 ± 0.40   | < 1      | 7.1 ± 0.5       |    |  |     |  |
| CO <sub>2</sub>  | < 0.1    | < 0.020       | < 0.1    | < 0.020       | < 0.1    | < 0.020       | < 0.1    | 0.040 ± 0.005   |    |  |     |  |
| O <sub>2</sub>   | < 1      | 0.794 ± 0.023 | 1.1      | < 0.030       | 2.3      | 1.105 ± 0.033 | < 1      | < 0.030         |    |  |     |  |
| He               | < 10     | < 30          | < 10     | < 30          | 13       | < 30          | 15       | < 30            |    |  |     |  |
| NMH<br>C         | 0.14     | < 0.10        | 0.02     | < 0.10        | 0.03     | < 0.01        | 0.03     | < 0.1           |    |  |     |  |
| CH <sub>4</sub>  | 0.12     | < 0.020       | 0.41     | < 0.020       | 0.11     | < 0.020       | 0.14     | 0.0194 ± 0.0040 |    |  |     |  |

# Gravimetric filter analysis

- None of the samples were above the limit of 1 mg/kg H<sub>2</sub>
- Standard deviation on measurement from 0.1 to 0.3\*mg/kg
- Low H<sub>2</sub> amount increases uncertainty
- Recommended drying cycle from Hydac not sufficient for our type of filters
- Filters dried / weighted until no weight change

\*Before drying procedures were improved



# Filter SEM analysis

- Visually filters look clean, only traces in SEM
- Edge is compressed by the O-ring, but confirmed by SEM to not de-laminate (still contains same amount of fluor, but have less porosity)
- Holes in the filter indicates that particulates penetrates the filter
- Filters look noticeably different after use, but not dirty



# Conclusions

- Sampling can be carried out safely and without disrupting normal operations of the station
- Overall high purity of the hydrogen, some violations
- No obvious trends for impurities based on feedstock
  - Most regular impurities comes from operation?
- More capable laboratories will give better analysis
- Filter samples indicates low amount of particulates, but some penetration of the filter



# Available resources

- HYDRAITE deliverable D3.1
- Hycora project reporting
- Publications





[Acknowledgements...]

# THANK YOU



[metrohyve.eu](http://metrohyve.eu)



[hydraite.eu](http://hydraite.eu)

Ole S. Kjos

ole.kjos@sintef.no

+47 99300116