

Prenormative REsarch for Safe use of Liquid HYdrogen

Thomas Jordan, KIT

Joint Workshop on Liquid Hydrogen Safety - Bergen, Norway, 6 March 2019

Pre-normative REsearch for Safe use of Liquid HYdrogen



Air Liquide

INERIS

PRESLHY

Outline

- Motivation
- PRESLHY Overview
- WP3 Release
- WP4 Ignition
- WP5 Combustion
- Exploitation
- Closure

Motivation



- Scale-up of existing and new applications increase demand.
- Liquid hydrogen (LH2) provides larger densities and gains in efficiency over gaseous transport and storage.
- The hazards and risks associated with LH2 are different from the relatively well-known compressed gaseous hydrogen (CGH2).
 (There are indications for reduced risk potential compared to CGH2)
- PRESLHY project addresses the pre-normative research for a safer use of cryogenic and liquid hydrogen as energy carrier.




PRESLHY Objectives

- Report **initial state-of-the-art and knowledge gaps** with priorities wrt intended use of LH2
- Execute adjusted experimental program addressing release, ignition and combustion phenomena with highest priorities
- Document and publish detailed, aggregated and interpreted data in a FAIR way
- Develop suitable models and engineering correlations and integrate them in a suitable open risk assessment toolkit
- Provide enhanced recommendations for safe design and operations of LH2 technologies
- Support international SDOs in

4

- updating of existing standards or
- developing of new international performance based and risk informed standards^{modern approach")}
- Document and disseminate the enhanced state-of-the-art




PRESLH




Participant orga	nisation name	Short name	Country
Karlsruher Institut für Technologie	Karlsruhe Institute of Technology	KIT	Germany
Air Liquide	Air Liquide	AL	France
HEALTH & SAFETY LABORATORY	Health & Safety Laboratory	HSL	United Kingdom
INTERNATIONAL ASSOCIATION FOR HYDROGEN SAFETY	International Association for Hydrogen Safety	HYSAFE	Belgium
INERIS	INERIS	INERIS	France
AT ANA	National Center for Scientific Research "Demokritos"	NCSRD	Greece
Pro-Science	Pro-Science GmbH	PS	Germany
Ulster University	University of Ulster	UU	United Kingdom
WARWICK THE UNIVERSITY OF WARWICK	The University of Warwick	UWAR	United Kingdom

Advisor name	Company Institution	Nation			
Derek Miller	Air Products	US			
Andrei Tchouvelev	AVT	CAN			
Klaus Schäfer	DLR	D			
Franz Grafwallner	ET	D			
Trygve Skjold	GexCon	N			
Karl Verfondern	Jülich	D			
Shoji Kamiya	KHI	JP			
Salvador Aceves	LLNL	US			
Lee Philips	Shell	UK			
Ethan Hecht	SNL	US			
Christoph Haberstroh	Uni Dresden	D			
Olav Hansen	Loyds	N			
Gerd-Michael Würsig	DNV GL	D			
Pietro Moretto	JRC	NL			
Volker Schröder	BAM	D			
Steve Woods	NASA	US			




General Approach PRESLHY



Motivation - WP2 Results - WP4 Ignition - WP5 Combustion – Exploitation - Closure Visuals for RCS Priority Topics



02:50



8


Time (secs)

Motivation - WP2 Results - WP4 Ignition - WP5 Combustion - Exploitation - Closure RCS- Visuals for LH2 Separation Distance RESLHY




Density LH₂ / CGH₂ (@35MPa) Temperature -250°C Liquid Phase

- \rightarrow 4 t LH₂ vs. 0,5t CGH₂ per trailer
- → Cooling capacity at filling station
- → Transfer from vessel to vessel w/o loss of expended energy (e.g. pressurization)



Storage; approx. 1.000 kg



Hydraulics

Pump

Motivation - WP2 Results - WP4 Ignition - WP5 Combustion – Exploitation - Closure RCS Status - NFPA2:2016 LH2, Separation Distance LH2 HURDGEN TECHNOLOGIES CODE


	Total Bulk Liquefied Hydrogen [LH] Storage								
	39.7 gal to 3500 gal	150 L to 13,250 L	3501 gal to 15,000 gal	13,251 L to 56,781 L	15,001 gal to 75,000 gal	56,782 L to 283,906 L			
Type of Exposure	ft	m	ft	m	ft	m			
Group 1									
. Lot lines	25	6.6	50	15	1.	23			
 Air intakes [heating, ventilating, or air conditioning equipment (HVAC, compressors, other] Wall openings 	75	23	75	23	75	23			
Operable openings in buildings and structures	75	23	75	23	75	23			
. Ignition sources such as open flames and welding Group 2	50	15	50	15	50	15			
. Places of public assembly	75	23	75	23	75	23			
Parked cars (distance shall be measured from the	25	7.6	25	7.6	25	7.6			
container fill connection) Group 3	o the	ese n	umbe	ers ma	ke ser	se?			
Building or structure									
(a) Buildings constructed of noncombustible or	Vhat :	are c	orrect	t crite	ria / m	ethor			
	That i					CIIIO			
(1) Sprinkler, Ubuilding or structure or	5 ^a	1.5	5^{a}	1.5	5^{a}	1.5			
unsprinklered building or structure having noncombustible contents (2) Unsprinklered building or structure with combustible contents									
	25	7.6	50	15	75	23			
(i) Adjacent wall(s) with fire resistance rating less than 3 hours									
less than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater ^b	5	1.5	5	1.5	5	1			
less than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater ^b (b) Buildings of combastible construction	5			1.5		1 15			
 less than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater^b (b) Buildings of combastible construction (1) Sprinklered building or structure 	5 50	15	50	1.5 1	50	1. 15 30.5			
 less than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater^b (b) Buildings of combustible construction (1) Sprinklered building or structure (2) Supprimetered building or structure 	5			13		30.5			
 less than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater^b (b) Buildings of combastible construction (1) Sprinklered building or structure (2) Comparing rest building or structure Flammable gas storage or systems (other than 	5 50 50	15 15	50 75	1.5 1 3 23	50 100				
 less than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater^b (b) Buildings of compastible construction (1) Sprinklered building or structure (2) CompanyIered building or structure Flammable gas storage or systems (other than hydrogen) above or below ground 	5 50 50	15 15	50 75	13	50 100	30.5			
 ess than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater^b b) Buildings of compastible construction (1) Sprinklered building or structure (2) Chaptinklered building or structure Clammable gas storage or systems (other than hydrogen) above or below ground b) Between stationary liquefied hydrogen containers 	5 50 50 50	15 15 15	50 75 75	1 3 23	50 100 75	30.5 23			
 less than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater^b (b) Buildings of combastible construction (1) Sprinklered building or structure (2) Comparistered building or structure Flammable gas storage or systems (other than hydrogen) above or below ground Between stationary liquefied hydrogen containers 	5 50 50 50	15 15 15 1.5	50 75 75 5	1 3 23 1.5	50 100 75 5	30.5 23 1.5			
 less than 3 hours (ii) Adjacent wall(s) with fire resistance rating of 3 hours or greater^b (b) Buildings of combastible construction (1) Sprinklered building or structure (2) chaptimatered building or structure Flammable gas storage or systems (other than hydrogen) above or below ground Between stationary liquefied hydrogen containers All classes of flammable and combustible liquids (above ground and vent or fill openings if below ground)^c 	5 50 50 50	15 15 15 1.5	50 75 75 5	1 3 23 1.5	50 100 75 5	30.5 23 1.5			
 less than 3 hours (ii) Adjacent wall (s) with fire resistance rating of 3 hours or greater^b (b) Buildings of combastible construction (1) Sprinklered building or structure (2) Comparised building or structure Flammable gas storage or systems (other than hydrogen) above or below ground Between stationary liquefied hydrogen containers 0. All classes of flammable and combustible liquids (above ground and vent or fill openings if below 	5 50 50 5 5 50	15 15 15 1.5 15	50 75 75 5 75	1 3 23 1.5	50 100 75 5 100	30.5 23 1.5 30.5			

10 SH2IFT-PRESLHY Joint Workshop on LH2 Safety, 6 March 2019, Bergen, Norway

Motivation - WP2 Results - WP4 Ignition - WP5 Combustion – Exploitation - Closure RCS Status - EIGA Code of Practice for LH₂



i i i i i i i i i i i i i i i i i i i		
	ITEMS	DISTANCE (M)
1	90 min fire resistive walls	2.5
2	Technical and unoccupied buildings	10
3	Occupied buildings	20
4	Air compressor intakes, air conditioning	20
5	Any combustible liquids	10
6	Any combustible solids	10
7	Other LH2 fixed storage	1.5
8	Other LH2 tanker	3
9	Liquid oxygen storage	6
10	Flammable gas storage	8
11	Open flame, smoking, welding	10
12	Place of public assembly	20
13	Public establishments	60
14	Railroads, roads, property boundaries	10
15	Overhead power lines	10




Gaps / Weak points wrt cryogenic H₂ release PRESLHY Gaps

- No experiments for under-expanded release & dispersion from LH₂ storage (saturated or sub-cooled conditions)
- No Blowdown
- No droplet size measurements
- No velocities or fluctuations
- Very limited structure of two-phase jets close to the release
- Weak points in many past experiments
 - Release momentum not measured
 - Uncertainty on the discharge rates
 - Large variability or limited info about meteorological conditions
 - Only few concentrations and temperatures

LHY

PR

HEM / HNEM Two-Phase Choked Flow Modeling e.g. NASA test 1197 (P_0 =12.9 bar, T_0 =30.7 K)



WP3 Experimental Activities

KIT / PS

- Design and set-up of tests E3.1, E3.4
- HSL
 - Design of tests E3.5
- INERIS
 - Sharing of existing LHe experiments data
 - Excluded tests
 - test 0 for no humidity info
 - tests 1,2 for too large wind variation
 - tests 7-9 for no H1, H2, L info
 - Tests 3 and 6 selected for validation




Issue n°	duration (s)	Mass flow rate (kg/s)	Wind speed (m/s) at 3 m height	Humidity (%)	Temp (°C)	H1 (m)	H2 (m)	L (m)
0	60	1,5	6	7	16	3	5	20
1	50	1,4	$4,0\pm1,0$	86	17	5	17	50
2	52	1,4	$5,2\pm1,0$	90	17	5	17	50
3	52	2,1	3,0±0,5	84	12	12	32	80
4	43	2,1	4,0±0,5	84	12	7	35	75
5	34	2,1	5,5±0,5	88	12	7	30	70
6	43	2,1	4,5±0,5	88	11	7	30	70
7	63	1,2	$2,0\pm0,5$	85	12			
8	65	1,2	2,0±0,5	85	12			
9	71	2,2	$2,0\pm0,5$	85	12			

L the length of the cloud on the ground H_1 the height of the base of the cloud H_2 the height at the top of the cloud.

E3.1 DISCHA-Facility Setup






- Vessel and valve will be cooled from outside by LN2 pool ($T_{min} = 77K$)
- Release of cold CGH2 and LN2 from up to 20 MPa

16 SH2IFT-PRESLHY Joint Workshop on LH2 Safety, 6 March 2019, Bergen, Norway

E3.1 DISCHA-Facility

Release experiments combined with near- and far-field optical measurements (BOS, laser, shadow,...) of mixing



bns)


PRESLHY

4 m

E3.1 CRYO-Vessel

LN₂-shielded Cryo-vessel:

18



- top flange with pipework, controls under construction,
- safety valves replaced,
- safety check by TÜV Süd scheduled.



PRESLHY

E3.4 Pool-Facility / Planned ExperimentsPRESLHY


Ground

(Concrete, Earth, Sand)

Insulation (PU-Foam)

- Basin with size 50 x 50 cm with variation of ground material (e.g. concrete, earth or sand, to be defined!)
- LH2 release on surface in basin,
- As long as no LH2-pool is formed no significant increase in weight,
- LH2-release until weight increases (or LH2-reservoir is empty),
- When pool has formed LH2 supply is stopped,
- All frozen gases evaporate → loss of weight,
- In correlation with ground surface temperature evaporation of different species (LH2, LN2, LO2) might be distinguished (distillation),
- Using loss of weight over time for surface temperatures below 80 K might give evaporation rate for LH2.






E4.1 MIE Device (INERIS)


PRESLHY

- Triggered spark
- Current and voltage measured in the spark gap
- Inductance = 1 mH or zero
- Capacitance : variable
- From a few microjoules to 1 joule






E4.1 Ignition by hot surfaces/power (INERIS)



PRESLHY

E4.2 Electrostatic Ignition in jet (KIT)




Further ignition experiments



- E4.3 Electrostatic Ignition in plume (HSL)
- E4.4 Ignition above pool (KIT)
- E4.5 Condensed phase ignition (HSL)






E5.1: DISCHA Ignited Jet

Flammability, pressure and heat flux for ignited cold jet


- For the ignited experiments an ignition device will be added to the existing facilities.
- Selected experiments of the unignited series will be repeated with ignition,
- Parameters to be varied include:
 - Ignition position,
 - Ignition time.






E5.2: Combustion-Tube-Facility

Tube experiments for FA and DDT criteria for T down to 80K




• Front-Flange with ports for:




- Gas-Inlet
- Glow-Plug
- Thermocouple

- End-Flange with ports for:
 - Thermocouple
 - Pressure-Sensor
 - Gas-Outlet
- Along the tube 52 ports for:
 - Pressure Sensors (2 different types),
 - Phototransistors



E5.2: Combustion-Tube-Facility




- 2 different obstacles (BR 30% and BR 60%),
- obstacles will be positioned evenly along the complete tube length (spacing: 1 inner diameter of tube) via three thin threaded rods,
- obstacles were manufactured externally (already delivered).

E5.5: Integral test in congested space


Variables:


- LH2 pool or jet
- Congestion level
- Confinement level
- LH2 jet flow rate

Ignition source located just downstream of rig to limit inventory of unburnt gas prior to entry into the congestion rig, this is to limit noise Blockage ratio?



Pool in congestion rig






PRESLHY

Higher flow rate release into rig, larger orifice


30 SH2IFT-PRESLHY Joint Workshop on LH2 Safety, 6 March 2019, Bergen, Norway






PRESLHY

FAIR Data Management



Outreach




PRESLHY

Deliverables on www.preslhy.eu

lumber 🗘	Delivera ble ¢ (number)	Delivera ble name	Work package 🗘 number	Short name of lead participa nt	Туре	Dissemin ation level	Delivery date (month)	Num	ber 🤅	Delivera ble \$ (number)	Delivera ble name	Work package 🗘 number	Short name of lead participa nt	Туре	Dissemin ation level	Delivery date (month)								
D1	D1.1	Kick-off Meeting	1	KIT	OTHER	со	1	D4		D1.4	2nd Project Meeting	1	KIT	OTHER	со	9								
D2	D1.2	Website including internal communica tion tools	1	KIT	DEC	PU	3	D21		D3.4	Summary of experiment series E3.1 (Discharge)	3	PS	REPORT	СО	11								
D12	D2.1	RCS Analysis	2	HySafe	REPORT	PU	3	D27		D4.4	results Summary	4	INERIS	REPORT	со	11								
D13	D2.2	State of the Art Report	2	AL	REPORT	PU	3				of experiment series E4.1													
D14	D2.3	LH2 installation description	2	AL	REPORT	PU	4				(General ignition) results													
D15	D2.4	LH2 Research Priorities	2	HySafe	OTHER	PU	4	D9		D1.9	1st Annual Data Reporting	1	KIT	REPORT	СО	12								
B46	22.5	Workshop			050007	011		D5		D1.5	3rd Project Meeting	1	KIT	OTHER	CO	14								
D16	D2.5	Phenomen a Identificatio n and Ranking Table Analysis	2	AL	REPORT	PU	4	D36		D5.5	Summary of experiment series E5.2 results	5	PS	REPORT	со	toc								
D17	D2.6	Refined Work Program	2	AL	REPORT	PU	5	D35		D5.4	Summary of experiment series E5.1	5	PS	REPORT	CO	15								
D3	D1.3	Data Manageme	1	KIT	ORDP	PU	б			L	results													
		nt Plan Version 1.0 - Draft														D18		D3.1	Theory and Analysis of cryogenic hydrogen	3	NCSRD	REPORT	PU	18
D44	D6.6	Plan for Disseminati	б	ULster	REPORT	PU	6				release and dispersion													
		on, Communica tion and Exploitation						D24		D4.1	Theory and Analysis of Ignition with	4	HSE	REPORT	PU	18								
RESLH	Y Joint V	Worksho	op on LH	l2 Safety	y, 6 Ma	rch 2019	, Bergen,	Νοι			specific conditions related to cryogenic hydrogen													

33

www.ichs2019.com



Invitation to





COLLABORATION

HOSTING





ITALY









Acknowledgement



The PRESLHY project has received funding from the Fuel Cells and Hydrogen 2 Joint Undertaking under the European Union's Horizon 2020 research and innovation program under the grant agreement No 779613

