


Morphological implications of passive techniques in office buildings architecture




IEECB'10
Luca Finocchiaro
Frankfurt, 13 April 2010





2 MORPHOLOGICAL ANALYSIS

SHAPE COEFFICIENTS



- Servizi generali
- Diagnosi e cure
- Degenze



(1),(2) ● Compactness

$$C = \frac{S_{eq}}{S_g} = 4,836 \frac{V_t^{2/3}}{S_g} \leq 1$$

$$S_g / V_t \text{ (m}^{-1}\text{)}$$

(3) ● Slenderness

$$e = \frac{h}{d} = \frac{h}{\sqrt{\left(\frac{S_0}{\pi} + h^2\right)}}$$

(4) ● Wall/Volume

$$S_w / V_t \text{ (m}^{-1}\text{)}$$


3 CASE STUDIES

THERMAL DEMAND


Foto	3D	Heated surface (HS)	Exposed surface (EA)	Glass area (GA)	window/wall ratio (GA/HS)	Double-facade*	Superwindow	Double facade**	Earth coupling	Heat pump	Hybrid ventilation	Passive cooling	PV-roof	Biomass	Thermal collector	Demand control	District heat
		Bravida 6300	5585,5	1080	32,30	X	X								X	X	X
		Year of constr. 2003			A/V 0,32												
		Location Fredrikstad			Compactness 0,52												
		Heating demand 67,45 KWh/m2y			Slenderness 0,37												
		Cooling demand 12,26 KWh/m2y			EA/V 0,14												
		Hamar Radhus 10500	6183,3	1300	31,80	X	X										
		Year of constr. 2001			A/V 0,26												
		Location Hamar Kommune			Compactness 0,59												
		Heating demand			Slenderness 0,57												
		Cooling demand			EA/V 0,13												
		Miljøsentret 15000	18827,3	2700	24,40	X	X			X	X	X	X	X	X	X	X
		Year of constr. 2006			A/V 0,22												
		Location Oslo - Blindern			Compactness 0,44												
		Heating demand 35 KWh/m2y			Slenderness 0,34												
		Cooling demand 4 KWh/m2y			EA/V 0,09												
		MMS Horten 3700	3654,1	700	27,40					X							
		Year of constr. 1996			A/V 0,34												
		Location Horten			Compactness 0,59												
		Heating demand 32 KWh/m2y			Slenderness 0,61												
		Cooling demand 7 KWh/m2y			EA/V 0,19												
		Nydalsspynten 2700	2537,1	428,7	40,80	X					X	X	X	X	X	X	X
		Year of constr. 2008			A/V 0,28												
		Location Oslo			Compactness 0,65												
		Heating demand 32 KWh/m2y			Slenderness 0,64												
		Cooling demand 0 KWh/m2y			EA/V 0,06												
		Røstad 3697	5121,6	1000	30,60			X	X								
		Year of constr. 2002			A/V 0,39												
		Location Levanger			Compactness 0,47												
		Heating demand 111,4 KWh/m2y			Slenderness 0,41												
		Cooling demand 0 KWh/m2y			EA/V 0,18												
		Sig. Halvorsen 3600	3763	600	30,60					X							
		Year of constr. 2006			A/V 0,42												
		Location Sandnes			Compactness 0,49												
		Heating demand 100,0 KWh/m2y			Slenderness 0,29												
		Cooling demand 0 KWh/m2y			EA/V 0,15												
		Telenor Kokstad 26800	22161,7	4800	29,00	X	X	X									X
		Year of constr. 2000			A/V 0,29												
		Location Bergen			Compactness 0,37												
		Heating demand			Slenderness 0,39												
		Cooling demand			EA/V 0,17												
		Vestveien 3200	3160,3	660	28,60	X	X	X	X								
		Year of constr. 2008			A/V 0,33												
		Location Ski			Compactness 0,64												
		Heating demand 23 KWh/m2y			Slenderness 0,66												
		Cooling demand 0 KWh/m2y			EA/V 0,19												
		Prof Brochs Gt 11450	10028	2200	28,80				X	X	X						
		Year of constr. 2009			A/V 0,31												
		Location Trondheim			Compactness 0,45												
		Heating demand 20,5 KWh/m2y			Slenderness 0,54												
		Cooling demand 8,2 KWh/m2y			EA/V 0,19												
		Sparebank 1 15600	8230	2138	41,80			X									X
		Year of constr. 2010			A/V 0,21												
		Location Trondheim			Compactness 0,61												
		Heating demand 25 KWh/m2y			Slenderness 0,49												
		Cooling demand 3 KWh/m2y			EA/V 0,09												

* Double skin for reduction of energy demand
 ** Solar energy double skin

a) Heating demand






b) Cooling demand




4 METHODOLOGY


27 OFFICE UNITS




a) Ground floor



b) Intermediate floors




c) roof




Climate: Oslo; Lat. 59.9°, Lng. 10.6°

- Corner zones present a higher request for heating due to the larger dispersions happening through the more extended glass surface
- In central zones the need for cooling represent almost 50% of the total thermal demand.
- Not significant differences could be appreciated in relation to the vertical position of the units.

5 CALIBRATION



1 The simulation tool used has been compared with another software – SIMIEN – and some monitored data



2 Dividing thermal zones into units


Significant differences could be appreciated:
a) dividing the corner units in two triangular thermal zones
b) calculating the thermal demand of the entire corner units and then dividing the result in two

6 THEORETICAL MODELS


THERMAL DEMAND

	Theoretical model	Heated surface (HS)	Exposed surface (EA)	Glass area (GA)	(GA/HS)	Heating demand	Cooling demand
Deep plan	01 - Block 6-6-5	4500	2700	720	16,00	30,04	17,96
	N, S	16				A/V 0,27	
	E, W	14				Compactness 0,76	
	NE,NW,SE,SW	2				Slenderness 0,66	
	Central	112				EA/V 0,13	
	02 - Block 6-10-3	4500	2940	576	12,80	29,14	17,3
N, S	24				A/V 0,33		
E, W	12				Compactness 0,62		
NE,NW,SE,SW	3				Slenderness 0,38		
Central	96				EA/V 0,11		
03 - Slab 9-10-2	4500	3390	456	10,13	28,64	16,41	
N, S	16				A/V 0,47		
E, W	14				Compactness 0,43		
NE,NW,SE,SW	2				Slenderness 0,22		
Central	112				EA/V 0,08		
04 - Atrio 8-8-3	4500	3300	720	16,00	30,15	17,38	
N, S	24				A/V 0,36		
E, W	24				Compactness 0,57		
NE,NW,SE,SW	3				Slenderness 0,38		
Central	72				EA/V 0,13		
05 - Atrio 6-7-5	4500	3600	1080	24,00	32,49	18,14	
N, S	40				A/V 0,33		
E, W	30				Compactness 0,61		
NE,NW,SE,SW	5				Slenderness 0,66		
Central	20				EA/V 0,20		
06 - Tower 4-4-12	4500	3160	1104	24,53	33,1	18,49	
N, S	22				A/V 0,26		
E, W	22				Compactness 0,77		
NE,NW,SE,SW	12				Slenderness 0,96		
Central	44				EA/V 0,20		
3M depth	07 - Tower 3-3-20	4500	3825	1440	32,00	36,2	18,61
	N, S	20				A/V 0,30	
	E, W	20				Compactness 0,68	
	NE,NW,SE,SW	20				Slenderness 0,99	
Central	20				EA/V 0,27		
08 - Bar 3-12-5	4500	3150	900	20,00	31,17	18,08	
N, S	50				A/V 0,30		
E, W	5				Compactness 0,68		
NE,NW,SE,SW	5				Slenderness 0,66		
Central	50				EA/V 0,17		
09 - Bar 3-6-10	4500	3150	1080	24,00	32,73	18,48	
N, S	40				A/V 0,27		
E, W	10				Compactness 0,76		
NE,NW,SE,SW	10				Slenderness 0,93		
Central	40				EA/V 0,20		
10 - H - 8-10-3	4500	3570	828	18,40	31,18	17,37	
N, S	27				A/V 0,38		
E, W	18				Compactness 0,54		
NE,NW,SE,SW	6				Slenderness 0,38		
Central	66				EA/V 0,15		
2M depth	11 - Bar 2-18-5	4500	3900	1200	26,67	33,14	18,25
	N, S	80				A/V 0,36	
	E, W	0				Compactness 0,57	
	NE,NW,SE,SW	5				Slenderness 0,66	
Central	0				EA/V 0,22		
12 - Bar 2-9-10	4500	3750	1320	29,33	34,29	18,6	
N, S	70				A/V 0,31		
E, W	0				Compactness 0,65		
NE,NW,SE,SW	10				Slenderness 0,93		
Central	0				EA/V 0,24		
13 - Tower 2-2-45	4500	5500	2160	48,00	43,65	18,47	
N, S	0				A/V 0,42		
E, W	0				Compactness 0,49		
NE,NW,SE,SW	45				Slenderness 0,99		
Central	0				EA/V 0,40		

a) Heating demand







b) Cooling demand



7 LE STRATEGIES

TYPOLOGIES





Implications of the shape on the thermal demand are negligible if compared with those ones consented by the adoption of a certain low energy strategy

8 HEATING AND COOLING DEMAND


<i>Unit</i>	Ref.	TEK07	LE	
$W/m^2/K$	1.2	0.15	0.15	U-value external wall
$W/m^2/K$	0.60	0.13	0.13	U-value roof
$W/m^2/K$	0.50	0.18	0.18	U-value floor on ground
$W/m^2/K$	2.4	1.2	1.2	U-value windows, glasses
<i>ach</i>	3.0	1.5	0.6	Air-tightness
-	0.7	0.7	0.85	Heat recovery syst. efficiency
<i>Pers./m²</i>	0.1	0.1	0.1	Occupancy
$^{\circ}C$	26	26	26	Cooling set point temperature
$^{\circ}C$	18	18	18	Heating set back temperature
W/m^2	8	8	8	Lighting load
W/m^2	11	11	11	Equipment load

tendency to use airtight envelopes is affecting the traditional presumption of total convenience of compact shapes in cold climates


9 HEATING AND COOLING DEMAND



a) REF



b) TEK07




c) LE


- Importance of using strategies for reducing the cooling demand or coping with it.

- Completely different behaviour between heating and cooling demand in relation to the form in case of ach=0,6


- Morphological implications




a) heating demand - 2,5 ach




b) heating demand - 1,5 ach




c) heating demand - 0,6 ach



a) cooling demand - 2,5 ach



b) cooling demand - 1,5 ach



c) cooling demand - 0,6 ach