




1

Relation between shape and energy use in low energy office buildings.





2 MORPHOLOGICAL ANALYSIS

SHAPE COEFFICIENTS



■ Servizi generali
■ Diagnosi e cure
■ Degenze



(1),(2) Compactness

$$C = \frac{S_{eq}}{S_g} = 4,836 \frac{V_t^{2/3}}{S_g} \leq 1$$

$$S_g / V_t (m^{-1})$$

(3) Slenderness

$$e = \frac{h}{d} = \frac{h}{\sqrt{\left(\frac{S_0}{\pi} + h^2\right)}}$$

(4) Wall/Volume

$$S_w / V_t (m^{-1})$$

3 CASE STUDIES


THERMAL DEMAND

Foto	3D	Heated surface (HS)	Exposed surface (EA)	Glass area (GA)	window/wall ratio (GA/HS)	Double-facade*	Superwindow	Double facade**	Earth coupling	Heat pump	Hybrid ventilation	Passive cooling	PV-roof	Biomass	Thermal collector	Demand control	District heat
		Bravida	6300	5585,5	1080	32,30	X	X		X	X	X	X	X	X	X	X
		Year of constr.	2003					A/V 0,32									
		Location	Fredrikstad					Compactness 0,52									
		Heating demand	67,45 KWh/m ² y					Slenderness 0,37									
		Cooling demand	12,26 KWh/m ² y					EA/V 0,14									
		Hamar Radhus	10500	6183,3	1300	31,80	X	X									
		Year of constr.	2001					A/V 0,26									
		Location	Hamar Kommune					Compactness 0,59									
		Heating demand						Slenderness 0,57									
		Cooling demand						EA/V 0,13									
		Miljøsentret	15000	18827,3	2700	24,40	X	X		X	X	X	X	X	X	X	X
		Year of constr.	2006					A/V 0,22									
		Location	Oslo - Blindern					Compactness 0,44									
		Heating demand	35 KWh/m ² y					Slenderness 0,34									
		Cooling demand	4 KWh/m ² y					EA/V 0,09									
		MMS Horten	3700	3654,1	700	27,40			X								
		Year of constr.	1996					A/V 0,34									
		Location	Horten					Compactness 0,59									
		Heating demand	32 KWh/m ² y					Slenderness 0,61									
		Cooling demand	7 KWh/m ² y					EA/V 0,19									
		Nydalspynten	2700	2537,1	428,7	40,80	X			X	X	X	X	X	X	X	X
		Year of constr.	2008					A/V 0,28									
		Location	Oslo					Compactness 0,65									
		Heating demand	32 KWh/m ² y					Slenderness 0,64									
		Cooling demand	0 KWh/m ² y					EA/V 0,06									
		Røstad	3697	5121,6	1000	30,60		X	X								
		Year of constr.	2002					A/V 0,39									
		Location	Levanger					Compactness 0,47									
		Heating demand	111,4 KWh/m ² y					Slenderness 0,41									
		Cooling demand	0 KWh/m ² y					EA/V 0,18									
		Sig. Halvorsen	3600	3763	600	30,60			X								
		Year of constr.	2006					A/V 0,42									
		Location	Sandnes					Compactness 0,49									
		Heating demand	100,0 KWh/m ² y					Slenderness 0,29									
		Cooling demand	0 KWh/m ² y					EA/V 0,15									
		Telenor Kokstad	26800	22161,7	4800	29,00	X	X	X							X	
		Year of constr.	2000					A/V 0,29									
		Location	Bergen					Compactness 0,37									
		Heating demand						Slenderness 0,39									
		Cooling demand						EA/V 0,17									
		Vestveien	3200	3160,3	660	28,60	X	X	X	X							
		Year of constr.	2008					A/V 0,33									
		Location	Ski					Compactness 0,64									
		Heating demand	23 KWh/m ² y					Slenderness 0,66									
		Cooling demand	0 KWh/m ² y					EA/V 0,19									
		Prof Brochs Gt	11450	10028	2200	28,80		X	X	X							
		Year of constr.	2009					A/V 0,31									
		Location	Trondheim					Compactness 0,45									
		Heating demand	20,5 KWh/m ² y					Slenderness 0,54									
		Cooling demand	8,2 KWh/m ² y					EA/V 0,19									
		Sparebank 1	15600	8230	2138	41,80		X								X	
		Year of constr.	2010					A/V 0,21									
		Location	Trondheim					Compactness 0,61									
		Heating demand	25 KWh/m ² y					Slenderness 0,49									
		Cooling demand	3 KWh/m ² y					EA/V 0,09									


* Double skin for reduction of energy demand

** Solar energy double skin

a) Heating d.






b) Cooling d.




4 METHODOLOGY


27 OFFICE UNITS




a) Ground floor



b) Intermediate fl.




c) roof



- Corner zones: higher request for heating
- Central zones: need for cooling represent almost 50% of the total thermal demand.
- Vertical location: not really affecting


1

Comparison with SIMIEN and monitored data



2

Dividing thermal zones into units



Corners:

a) two triangular thermal zones


b) Dividing thermal demand in two

6 THEORETICAL MODELS


	Theoretical model	Heated surface (HS)	Exposed surface (EA)	Glass area (GA)	(GA/HS)	Heating demand	Cooling demand
Deep plan	01 - Block 6-6-5	4500	2700	720	16,00	30,04	17,96
	N, S	16			A/V 0,27		
	E, W	14			Compactness 0,76		
	NE,NW,SE,SW	2			Slenderness 0,66		
	Central	112			EA/V 0,13		
	02 - Block 6-10-3	4500	2940	576	12,80	29,14	17,3
Deep plan	N, S	24			A/V 0,33		
	E, W	12			Compactness 0,62		
	NE,NW,SE,SW	3			Slenderness 0,38		
	Central	96			EA/V 0,11		
	03 - Slab 9-10-2	4500	3390	456	10,13	28,64	16,41
	N, S	16			A/V 0,47		
Deep plan	E, W	14			Compactness 0,43		
	NE,NW,SE,SW	2			Slenderness 0,22		
	Central	112			EA/V 0,08		
	04 - Atrio 8-8-3	4500	3300	720	16,00	30,15	17,38
	N, S	24			A/V 0,36		
	E, W	24			Compactness 0,57		
Deep plan	NE,NW,SE,SW	3			Slenderness 0,38		
	Central	72			EA/V 0,13		
	05 - Atrio 6-7-5	4500	3600	1080	24,00	32,49	18,14
	N, S	40			A/V 0,33		
	E, W	30			Compactness 0,61		
	NE,NW,SE,SW	5			Slenderness 0,66		
3M depth	Central	20			EA/V 0,20		
	06 - Tower 4-4-12	4500	3160	1104	24,53	33,1	18,49
	N, S	22			A/V 0,26		
	E, W	22			Compactness 0,77		
	NE,NW,SE,SW	12			Slenderness 0,96		
	Central	44			EA/V 0,20		
3M depth	07 - Tower 3-3-20	4500	3825	1440	32,00	36,2	18,61
	N, S	20			A/V 0,30		
	E, W	20			Compactness 0,68		
	NE,NW,SE,SW	20			Slenderness 0,99		
	Central	20			EA/V 0,27		
	08 - Bar 3-12-5	4500	3150	900	20,00	31,17	18,08
3M depth	N, S	50			A/V 0,30		
	E, W	5			Compactness 0,68		
	NE,NW,SE,SW	5			Slenderness 0,66		
	Central	50			EA/V 0,17		
	09 - Bar 3-6-10	4500	3150	1080	24,00	32,73	18,48
	N, S	40			A/V 0,27		
3M depth	E, W	10			Compactness 0,76		
	NE,NW,SE,SW	10			Slenderness 0,93		
	Central	40			EA/V 0,20		
	10 - H - 8-10-3	4500	3570	828	18,40	31,18	17,37
	N, S	27			A/V 0,38		
	E, W	18			Compactness 0,54		
2M depth	NE,NW,SE,SW	6			Slenderness 0,38		
	Central	66			EA/V 0,15		
	11 - Bar 2-18-5	4500	3900	1200	26,67	33,14	18,25
	N, S	80			A/V 0,36		
	E, W	0			Compactness 0,57		
	NE,NW,SE,SW	5			Slenderness 0,66		
2M depth	Central	0			EA/V 0,22		
	12 - Bar 2-9-10	4500	3750	1320	29,33	34,29	18,6
	N, S	70			A/V 0,31		
	E, W	0			Compactness 0,65		
	NE,NW,SE,SW	10			Slenderness 0,93		
	Central	0			EA/V 0,24		
2M depth	13 - Tower 2-2-45	4500	5500	2160	48,00	43,65	18,47
	N, S	0			A/V 0,42		
	E, W	0			Compactness 0,49		
	NE,NW,SE,SW	45			Slenderness 0,99		
	Central	0			EA/V 0,40		

THERMAL DEMAND

a) Heating d.







b) Cooling d.



7 L-E STRATEGIES

TYPES



Negligible influence of the shape ?

8 HEATING AND COOLING DEMAND


STANDARDS

Unit	Ref.	TEK07	LE	
$W/m^2/K$	1.2	0.15	0.15	U-value external wall
$W/m^2/K$	0.60	0.13	0.13	U-value roof
$W/m^2/K$	0.50	0.18	0.18	U-value floor on ground
$W/m^2/K$	2.4	1.2	1.2	U-value windows, glasses
<i>ach</i>	3.0	1.5	0.6	Air-tightness
-	0.7	0.7	0.85	Heat recovery syst. efficiency
<i>Pers./m²</i>	0.1	0.1	0.1	Occupancy
$^{\circ}C$	26	26	26	Cooling set point temperature
$^{\circ}C$	18	18	18	Heating set back temperature
W/m^2	8	8	8	Lighting load
W/m^2	11	11	11	Equipment load

compact shapes in
cold climates ?

9 HEATING AND COOLING DEMAND

SHAPE



-Strategies for cooling

-Different behaviour of heating and cooling demand

-Morphological implications